GLOBAL ANALYTICAL LABORATORY

33/2, SHOP: 13, CRS BUILDING, C RAMAIAH LAYOUT, RAMACHANDRAPURA MAIN ROAD,
VIDYARANYAPURA, BENGALURU – 560097, MOBILE: 9686489581 / 9353971722
Email : globaltestinglab2020@gmail.com

INVOICE

DATE: 25.06.2022

FROM	TO
M/S GLOBAL ANALYTICAL LABORATORY # 33/2, C.R.S BUILDING , C RAMAIAH LAYOUT, VIDYARANYAPURA, B/LORE- 560097 GST : 29FPRPP6312H1ZA	M/S SHREE RANGA ENTERPRISES BBMP CONTRACTOR KALLIPALYA, MADIGONDANAHALLI POST KUDUR HOBLI ,MAGADI TALUK,RAMANAGAR DIST GST : 29AFGPV7996D2ZK INVOICE : GAL/06/1888

PARTICULARS	QTY	PRICE	TOTAL
ANALYSIS CHARGES FOR PHYSICAL , CHEMICAL MICROBIOLOGICAL TEST	1	3600	3600.00
CGST 9%			324.00
SGST 9%			324.00

Global Analytical Laboratory
BANK DETAILES : CANARA BANK
A/c : 9921201002655
IFSC : CNRB0002615
VIDYARANYAPURA BRANCH

GOOGLE PAY OR PHONE PAY
9686489581 PALLAVI RAO

FOUR THOUSAND TWO HUNDRED FOURTY EIGHT RUPEES ONLY

TOTAL - 4248.00

GLOBAL ANALYTICAL LAB ★ Vidyaranyapura, Bangalore-97 ★

Scanned with CamScanner

GLOBAL ANALYTICAL LABORATORY

ISO 9001 : 2015

33/2, Shop No. 13, C R S Building, C Ramaiah Layout, Ramachandrapura Main Road, Vidyaranyapura, Bangalore - 560 097 Mob : 9686489581, 9353921722

E-mail : globaltesting2020@gmail.com

TEST REPORT

Report No : GAL/06/1888
Name : MR NAGESH V
PURE DRINKING WATER WARD - 14
Address:13TH CROSS, SIR M VISHWESHWARAIAH LAYOUT, BAGALGUNTE , BENGALURU

Report Date : 29.06.2022
Sample Collected on : 25.06.2022
Sample Tested on : 25.06.2022
Sample particulars : BOREWELL WATER

The water sample collected & analyzed by us with the following results:

SAMPLE DESCRIPTION: Colorless , Odorless , and Transparent Liquid

PARAMETERS As per IS 10500:2012	RESULTS	Maximum Acceptable Limits (In mg/l)	Maximum Permissible Limits (In mg/l)	PROTOCOL IS 3025
PHYSICAL TEST				
Color,	<5	5	25	IS-3025/Part-4
Odor	Agreeable	Agreeable	----	IS-3025/Part-5
Total Dissolved solids, mg/l	790	500	2000	IS-3025/Part-16
Turbidity, NTU	0.9	1	5	IS-3025/Part-10
Taste	Agreeable	Agreeable	Agreeable	IS-3025/Part-8
Suspended solids	13	8	30	IS-3025/Part-17
CHEMICAL TEST				
CATIONS				
Calcium as Ca , mg/l	135	75	200	IS-3025/Part-40
Magnesium, mg/l	53	30	100	IS-3025/Part-48
Sodium as Na	90	50	70	----------
Potassium as K	2	10	10	----------
Iron as Fe , mg/l	0.13	0.3	1	IS-3025/Part-53
ANIONS				
Chloride as Cl, mg/l	114.5	250	1000	IS-3025/Part-32
Sulphate as SO4 , mg/l	20	200	400	IS-3025/Part- 24
Fluoride as F , mg/l	0.79	1	1.5	IS-3025/Part- 60
Conductivity as Micro/ µhos	3160	2000	4000	IS-3025/Part
Manganese as Mn , mg/l	<0.1	0.1	0.15	IS-3025/Part-59
Dissolved Oxygen	6.8	6	7.5	IS-3025/Part

Tested By

GLOBAL ANALYTICAL LAB

Authorised Signature

Note : 1. The results listed above pertain only to the tested samples and applicable parameters. 2. Samples will be stored for a period of 15 days unless otherwise specified. 3. This report is not to be reproduced either wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without prior written permission. 4. Sampling not done by us unless specified

Scanned with CamScanner

GLOBAL ANALYTICAL LABORATORY

ISO 9001 : 2015

33/2, Shop No. 13, C R S Building, C Ramaiah Layout, Ramachandrapura Main Road, Vidyaranyapura, Bangalore - 560 097. Mob : 9686489581, 9353921722

E-mail . globaltesting2020@gmail.com

PARAMETERS	Results mg/l	Maximum Acceptable Limits (In mg/l)	Maximum Permissible Limits (In mg/l)	PROTOCOL-3025
Residual Chlorine	0.16	0.2	0.3	IS-3025/Part-26
Total Hardness as CaCo3	460	200	600	IS-3025/Part-21
Silica as Sio2	85	100	150	IS-3025
Ph	6.7	6.5 – 8.5	6.5- 8.5	IS-3025/Part-11
Lead as Pb	<0.1	0.1	1	IS-3025/Part-47
Zinc as Zn	<0.1	0.1	5	IS-3025/Part-49
Phenolphthalein Alkalinity	NIL	--------	-------	IS-3025/Part-23
Chromium	<0.05	0.05	0.05	IS-3025/Part-52
Alkalinity as CaCo3	218	200	400	IS-3025/Part-23
Aluminium as Al	<0.03	0.03	0.03	IS-3025/Part-55
Boron as B	<0.01	0.01	0.1	ALPHA
Free Ammonia	NIL	NIL	NIL	IS-3025/Part-34
Total Nitrogen	23	30	35	IS-3025
Copper as Cu	<0.05	0.05	1.5	IS-3025/Part- 42
Total Organic Carbon	NIL	NIL	-------	IS-3025
Nitrate as NO3	17	45	45	IS-3025/Part-34
Permanent Hardness	290	200	400	IS- 3025/part-40
Tempe vary Hardness	170	100	200	IS-3025/part-46

MICROBIOLOGICAL TEST

TESTS	RESULT	Limits as per IS 10500 – 2012	Protocol
Total Coli form / 100ml	NIL	Not Detectable	IS – 1622 - 3025
E-Coli Coli form	Absent	Absent	IS- 1622 - 3025
REMARKS: The given water sample is Microbiologically safe.			

REMARK: The given sample above parameters are tested as per IS 10500 -2012 and it is physical, chemical Test. The water does not confirm IS - Acceptable Limits.

Tested By

GLOBAL ANALYTICAL LAB ★ Vidyaranyapura Bangalore ★

Authorised Signature

Note : 1. The results listed above pertain only to the tested samples and applicable parameters. 2. Samples will be store for a period of 15 days unless otherwise specified. 3. This report is not to be reproduced either wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without prior written permission. 4. Sampling not done by us unless specified

Scanned with CamScanner